



# RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-ULTRABLADEPRO

Date: 28 May 2021

We: 

Clevertronics Pty Ltd 1 Caribbean Drive Scoresby VIC 3179 Australia T: +61 3 9559 2700 E: <a href="mailto:Productenquiry@clevertronics.com.au">Productenquiry@clevertronics.com.au</a> ABN: 64 136 264 349	Clevertronics Pty Ltd Unit 22/761 Great South Road Penrose, Auckland 1061, New Zealand T: +64 800 548 448 E: <a href="mailto:Productenquiry@clevertronics.com.au">Productenquiry@clevertronics.com.au</a> NZBN: 9429042377382
--	---

declare that the CUBPRO-HV and following associated product codes

CUBPRO-vv-xx-uu-yy-zz  
CUBPRO-vv-TH-xx-ww-zz  
LUBPRO-vv-xx-uu-yy-zz  
LUBPRO-vv-TH-xx-ww-zz  
CUBPRO-SM-WP-xx-uu-zz  
LUBPRO-SM-WP-xx-uu-zz

Where,

uu = Blank	Fitting with Horizontal Decal (default)
uu = V	Fitting with Vertical Decal
vv = Blank	Recessed fitting
vv = SM	Surface Mount fitting
vv = RS	Rod Suspended fitting
xx = Blank	Manual Test/Clevertest Plus (CTP)
xx = ZW	Zoneworks
xx = HV	Zoneworks XT HIVE
xx = DATA	Zoneworks DATA
xx = DALI	DALI Registered
yy = Blank	Housing Colour- Default
yy = BLK	Housing Colour- BLACK
zz = Blank	Normal Fitting
zz = UPS	Fitting with Uninterruptible Power Supplies
zz = 4HR	Normal Fitting with 4-hour emergency running time
ww = Blank	One-box Solution
ww = E	EXIT Decal
ww = SP	Special Decal
ww = R	Running Man Decal
ww = RL	Running Man Left Arrow Decal
ww = RR	Running Man Right Arrow Decal
ww = DS-E	Double sided EXIT Decal
ww = DS-R	Double sided Running Man Decal
ww = DS-RL	Double sided Running Man Left Decal
ww = DS-RR	Double sided Running Man Right Decal
ww = DS-RAOW	Double sided Running Man Arrow One Way Decal



## RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC)

The above products meet the following standards:

AS/NZS 2293.3:2018	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS 60598.2.22:2019	Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)
AS CISPR 15:2017	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

**Michael Duce**  
National Systems and Engineering  
Manager

